

Report Index: REHLKO-20250720-184329-79

General Information

Report Type:	emergency
Generator Serial Number:	343CGSKR0001
Customer Name:	Infineum
Problem Issue:	Fuel leakage
Running Hours:	35
Load Test:	Yes
Load Hour:	1
Load Amount:	1500
Used For:	
Error Code:	10047
Test Run:	No
Location:	
Layer:	
Remarks:	
Status:	completed
Engineer:	Kelvin
Supervisor:	Thet Min Hein
Created Date:	2025-07-20 06:43:29

Root Cause

â€¢ cross thread

Corrective Actions

No corrective actions taken.

Effective Actions

â€¢ solved

Prevention

â€¢ quality

Suggestions

â€¢ NA